

Test Verification of Conformity

Verification Number: 260429090GZU-VOC002

On the basis of the tests undertaken, the sample<s> of the below product has been tested by an accredited 3rd party laboratory in accordance to the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	Ersutek Isitma Sogutma Aritma Enerji Ins. Taah. San. ve Tic. Ltd. Sti Ostim Mah. 1261. Sok. NO: 10 Yenimahalle ANKARA TURKEY
Product Description:	Heat Pump
Ratings & Principle Characteristics:	380 - 415V 3N~, 50Hz, Class I, IPX4, ERS290-50CHT: 19,3kW, 35,0A, R290: 3,1kg, ERS290-75CHT: 30,5kW, 54,5A, R290: 6,2kg, ERS290-100CHT: 40,5kW, 82,0A, R290: 6,8kg
Models/Type References:	ERS290-50CHT, ERS290-75CHT, ERS290-100CHT
Brand Names:	ERSUTEK
Specification<s>/Standards:	EN IEC 60335-2-40: 2023+A11:2023 Household and similar electrical appliances – Safety Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers EN 60335-1:2012 + A11:2014 + A13:2017 + A1:2019 + A2:2019 + A14:2019 + A15:2021 + A16:2023 Household and similar electrical appliances – Safety – Part 1: General requirements EN 62233:2008 Measurement methods for electromagnetic fields of household appliances and similar apparatus with regard to human exposure Machinery Directive 2006/42/EC Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Room 101/301/401/102/202/302/402/502/602/702/802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong, China
Verification Issuing Office Name & Address:	
Date of Tests:	March 11, 2026 to May 07, 2026
Test Report Number(s):	260429090GZU-001

Signature



Name: Kuboo Li

Position: Supervisor

Date: May 07, 2026

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.